



Canyon Fuel Company  
SUFCA Mine  
397 South 800 West  
Salina, UT 84654  
(435) 286-4880 Fax (435) 286-4499

February 9, 2000

Ms. Kelly Coleman  
Department of Environmental Quality  
Division of Water Quality  
288 North 1460 West  
P. O. Box 144870  
Salt Lake City, UT 84114-4870

Dear Ms. Coleman:

Enclosed are the January 2000, Discharge Monitoring Reports (DMR's) for the SUFCA Mine facility, permit number UT-0022918. Discharge point 001A had no outflow. The outflow from point 002A had an exceedance for the 30 day average on TSS. The average was 25.7 mg/l while the permit limit is 25 mg/l. Point 003A had no exceedances for the month.

Sincerely,  
CANYON FUEL COMPANY, LLC  
SUFCA Mine

Wesley K. Sorensen, P.E.  
Technical Services Manager

WKS:kb

Encl.: January DMR's

cc: Mary Ann Wright, DOGM  
Rob Mrowka, USFS  
Chris Hansen, Skyline  
Compliance Officer, U.S. EPA, Denver  
EPA Test Procedures & Water Monitoring File

Tracking -  
Ken -  
Mike -  
Dete -  
with  
ACT/04/002  
incoming