



Canyon Fuel Company  
SUFCO Mine  
397 South 800 West  
Salina, UT 84654  
(435) 286-4880 Fax (435) 286-4499

October 26, 2000

Ms. Kelly Coleman  
Department of Environmental Quality  
Division of Water Quality  
288 North 1460 West  
P. O. Box 144870  
Salt Lake City, UT 84114-4870

Dear Ms. Coleman:

Enclosed are the September 2000, Discharge Monitoring Reports (DMR's) for the SUFCO Mine facility, permit number UT-0022918. Discharge points 001A and 002A had no outflow. Point 003A had no exceedances for the month. The sampling of point 003A on September 20, 2000 reported a total iron level of 1.12 mg/l. This exceedance was reported to the Division as required by the permit. This exceedance was a large deviation from historic levels. The laboratory was asked to re-run the sample using the reserve. This re-test resulted in a total iron level below the detection limit of 0.2 mg/l. A copy of the re-test is included.

Biomonitoring was completed for Point 003 using ceriodaphnia during August.

Sincerely,  
CANYON FUEL COMPANY, LLC  
SUFCO Mine

Wesley K. Sorensen, P.E.  
Technical Services Manager

WKS:kb

Encl.: September DMR's

cc: Mary Ann Wright, DOGM  
Rob Mrowka, USFS  
Chris Hansen, Skyline  
Compliance Officer, U.S. EPA, Denver  
EPA Test Procedures & Water Monitoring File