



Canyon Fuel Company, LLC  
 SUFCO Mine  
 397 South 800 West  
 Salina, UT 84654  
 (435) 286-4880 Fax: (435) 286-4499

January 4, 2002

Mr. Don Ostler, Director  
 Department of Environmental Quality  
 Division of Water Quality  
 288 North 1460 West  
 P.O. Box 144870  
 Salt Lake City, Utah 84114-4870

RE: NPDES PERMIT UT-0022918

Dear Mr. Ostler:

According to the conditions of NPDES Discharge Permit UT-0022918, Part II-I-3 and Utah Coal Mining Rules R645-301-731.223, Canyon Fuel Company is providing the written notification of a failure to comply with the daily maximum limitation for TDS at outfall 003. The receiving stream for outfall 003 is Quitchupah Creek.

The daily maximum limit for TDS of 1200 mg/l was exceeded by the sample taken on December 19, 2001 with a TDS value of 1210 mg/l. This value is slightly less than the December 5, 2001 TDS value of 1220 mg/l. The cause of this high TDS is believed to be associated with poor water quality from the old 3 West area. The 4 East longwall block was sealed during September. This resulted in a temporary cessation of flow from this area, since the pumps were removed and the area is being allowed to flood. Water will eventually be discharged from the lowest seal point in our East Mains once the area is flooded. We plan to mix additional better quality water with the water from the 3 West area. The results of the December 19, 2001 sample were obtained by e-mail on January 3, 2002.

Sincerely,  
 CANYON FUEL COMPANY, LLC  
 SUFCO Mine

Wesley K. Sorensen, P.E.  
 Technical Services Manager

cc: Division of Oil, Gas & Mining  
 EPA - Water Management Division  
 Ken May  
 Chris Hansen

*Mike  
 Conner  
 Dorey  
 C/04/002*