



0010

Canyon Fuel Company  
SUFCO Mine  
397 South 800 West  
Salina, UT 84654  
(435) 286-4880 Fax (435) 286-4499

February 14, 2002

Ms. Kelly Coleman  
Department of Environmental Quality  
Division of Water Quality  
288 North 1460 West  
P. O. Box 144870  
Salt Lake City, UT 84114-4870

*incoming  
2/04/002  
FAX Cover to  
Letter  
PFO*

Dear Ms. Coleman:

Enclosed are the January 2002, Discharge Monitoring Reports (DMR's) for the SUFCO Mine facility, permit number UT-0022918. Discharge points 001A and 002A had no outflow during the month. The outflow from point 003A had one exceedance for the month on TDS. This exceedance of the TDS limit was reported as required by the UPDES permit. The sample taken on January 16, 2002 had a TDS value of 1240 mg/l, which is 40 mg/l above the permit limit. Corrective action was taken to by routing additional low TDS water into the underground sump thus lowering the TDS of the resultant discharge as evidenced by the January 30, 2002 sample with a TDS of 1170 mg/l.

Sincerely,  
CANYON FUEL COMPANY, LLC  
SUFCO Mine

Wesley K. Sorensen, P.E.  
Technical Services Manager

WKS:kb

Encl.: January DMR's  
cc: Mary Ann Wright, DOGM  
Mary Erickson, USFS Fishlake  
Chris Hansen, Skyline  
Compliance Officer, U.S. EPA, Denver  
EPA Test Procedures & Water Monitoring File

RECEIVED

FEB 25 2002

DIVISION OF  
OIL, GAS AND MINING