0059

Canyon Fuel Company, LLC.
Sufco Mine
A Subsidiary of Arch Western Bituminous Group, LLC.

John Byars
Technical Services Manager
397 South 800 West
Salina, UT 84654
(435) 286-4400 - Office
(435) 286-4499- Fax

RECEIVED
JUN 19 2006
6/20/06
DIV. OF OIL, GAS & MINING

Incoming
C0410002

June 12, 2006

Mr. Jeff Studenka
Department of Environmental Quality
Division of Water Quality
288 North 1460 West
P. O. Box 144870
Salt Lake City, UT 84114-4870

Dear Mr. Studenka:

Enclosed are the May 2006, Discharge Monitoring Reports (DMR's) for the SUFCO Mine facility, permit number UT-0022918. Discharge point 001A had no outflow during the month. The outflow from point 003A had no exceedances for the month.

The outflow from point 002A had a TSS exceedance for the month. The daily maximum limit for TSS of 70 mg/L was not exceeded because the sample taken on May 4, 2006, had a TSS value of 46 mg/L. This TSS value caused the seven-day average limit of 35 mg/L to be exceeded since this was the only sample taken during that week. The settleable solids sample taken had a value of <0.1 ml/L, which does not exceed the 0.5 ml/L limitation. The reason for the high TSS value is believed to be in part due to a light rain on that date.

Sincerely,
CANYON FUEL COMPANY, LLC
SUFCO Mine

John D. Byars
Technical Services Manager

JDB/MLD:kb

Encl.: May 2006 DMR's

cc: Mary Ann Wright, DOGM
Mary Erickson, USFS Fishlake
Chris Hansen, Skyline
Compliance Officer, U.S. EPA, Denver
EPA Test Procedures & Water Monitoring File

Sufpub:\Govt2006\DEQ\DMR LTR-0605.doc

PERMITEE NAME/ADDRESS
(Include Facility Name/Location if different)

NAME: Canyon Fuel Co., LLC
ADDRESS: SUFCO Mine
397 South 800 West
Salina, UT 84654
FACILITY: SUFCO Mine
LOCATION: SALINA

ATTN: KENNETH E. MAY, MINE MANAGER

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM *(NPDES)*
DISCHARGE MONITORING REPORT *(DMR)*

(2-16) UT0022918 — PERMIT NUMBER
(17-19) 001 A — DISCHARGE NUMBER

MAJOR
F - FINAL
Minesite
8" PIPE DISCHARGING MINE WATER

Form Approved
OMB No. 2040-0004

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
0 6	0 5	0 1	0 6	0 5	3 1
(20-21)	(22-23)	(24-25)	(26-27)	(28-29)	(30-31)

*** NO DISCHARGE [X] ***

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53) AVERAGE	(54-61) MAXIMUM	UNITS 0	(4 Card Only) QUALITY OR CONCENTRATION (38-45) MINIMUM	(46-53) AVERAGE	(54-61) MAXIMUM	UNITS	NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
FLOW RATE	SAMPLE MEASUREMENT			(03)	******	******	******				
00056 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT 30DA AVG	REPORT DAILY MX	MGD	******	******	******	**** ****		TWICE/ MONTH	MEASRD
PH	SAMPLE MEASUREMENT	*****	*****					(12)			
00400 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	******	******	**** ****	6.5 DAILY MN	******	9.0 DAILY MX	SU		TWICE/ MONTH	GRAB
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	*****	*****		******	******		(19)			
00530 P 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT	******	******	**** ****	0.5 ****** 30 DA AVE	35 ****** MX 7DAVE	70 DAILY MX	MG/L		TWICE/ MONTH	GRAB
SOLIDS, SETTLEABLE	SAMPLE MEASUREMENT	*****	*****					(25)			
00545 P 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT	******	******	**** ****	******	******	0.5 DAILY MX	MG/L		TWICE/ MONTH	GRAB
OIL AND GREASE FREON EXTR-GRAV MET	SAMPLE MEASUREMENT	*****	*****		*****	*****		(19)			
00556 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	******	******	**** ****	******	******	10 DAILY MX	MG/L		TWICE/ MONTH	GRAB
IRON, TOTAL (AS FE)	SAMPLE MEASUREMENT	*****	*****		*****	*****		(19)			
01045 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	******	******	**** ****	******	******	1.0 DAILY MX	MG/L		TWICE/ MONTH	GRAB
FLOATING SOLIDS OR VISIBLE FOAM-VISUAL	SAMPLE MEASUREMENT	******		(94)	******	******	******				
45613 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	******	0	YES=1 NO=0	******	******	******	****** ******		TWICE/ MONTH	VISUAL

NAME/TITLE PRINCIPLE EXECUTIVE OFFICER

KENNETH E. MAY
MINE MANAGER

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMAITON. I BELIEVE THE SUBMITTED INFORMATIONS IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE, AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statues may include fines up to $10,000 and or maximum imprisonment of between 6 months and 5 years.

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE		DATE		
435	286-4880	06	06	12
AREA CODE	NUMBER	YR	MO	DA

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

No Discharge during month of May 2006

PERMITEE NAME/ADDRESS
(Include Facility Name/Location if different)

NAME: Canyon Fuel Co., LLC
ADDRESS: SUFCO Mine
397 South 800 West
Salina, UT 84654
FACILITY: SUFCO Mine
LOCATION: SALINA

ATTN: KENNETH E. MAY, MINE MANAGER

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM *(NPDES)*
DISCHARGE MONITORING REPORT *(DMR)*

(2-16)	(17-19)
UT0022918	001 A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
0 6	0 5	0 1	0 6	0 5	3 1
(20-21)	(22-23)	(24-25)	(26-27)	(28-29)	(30-31)

MAJOR
F - FINAL
Minesite
8" PIPE DISCHARGING MINE WATER

Form Approved
OMB No. 2040-0004

*** NO DISCHARGE [X] ***

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53) AVERAGE	(54-61) MAXIMUM	UNITS 0	(4 Card Only) QUALITY OR CONCENTRATION (38-45) MINIMUM	(46-53) AVERAGE	(54-61) MAXIMUM	UNITS	NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
SANITARY WASTE DISCHARGED-ASSESSMENT	SAMPLE MEASUREMENT	*****		(94)	******	******	******				
45614 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT		0	YES=1 NO=0				**** ****		TWICE/ MONTH	VISUAL
SOLIDS, TOTAL DISSOLVED	SAMPLE MEASUREMENT	*****	*****		******	******		(19)			
70295 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT			**** ****			1200 DAILY MX	MGL		TWICE/ MONTH	GRAB
OIL AND GREASE VISUAL	SAMPLE MEASUREMENT	*****	*****	(94)	******	******	******				
84066 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT		0	YES=1 NO=0				**** ****		TWICE/ MONTH	VISUAL
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPLE EXECUTIVE OFFICER
KENNETH E. MAY
MINE MANAGER
TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMAITON. I BELIEVE THE SUBMITTED INFORMATIONS IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE, AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statues may include fines up to $10,000 and or maximum imprisonment of between 6 months and 5 years.

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE		DATE		
435	286-4880	06	06	12
AREA CODE	NUMBER	YR	MO	DA

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

No Discharge during month of May 2006

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT *(DMR)*

MAJOR

F - FINAL

Form Approved
OMB No. 2040-0004

ERMITEE NAME/ADDRESS
(Include Facility Name/Location if different)

NAME: Canyon Fuel Co., LLC
ADDRESS: SUFCO Mine
397 South 800 West
Salina, UT 84654
FACILITY: SUFCO Mine
LOCATION: SALINA

(2-16) UT0022918 — PERMIT NUMBER

(17-19) 002 A — DISCHARGE NUMBER

SEDIMENTATION POND
12" PIPE DISCHARGE FROM SEDIMENT POND

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
0 6	0 5	0 1	0 6	0 5	3 1
(20-21)	(22-23)	(24-25)	(26-27)	(28-29)	(30-31)

*** NO DISCHARGE [ ] ***

NOTE: Read instructions before completing this form.

ATTN: KENNETH E. MAY, MINE MANAGER

PARAMETER (32-37)		QUANTITY OR LOADING (3 Card Only) (46-53) AVERAGE	(54-61) MAXIMUM	UNITS 0	QUALITY OR CONCENTRATION (4 Card Only) (38-45) MINIMUM	(46-53) AVERAGE	(54-61) MAXIMUM	UNITS	NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
FLOW RATE	SAMPLE MEASUREMENT	0.006	0.009	(03)	******	******	******		0	2 /30	Measrd
00056 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT 30DA AVG	REPORT DAILY MX	MGD	******	******	******	**** ****		TWICE/ MONTH	MEASRD
PH	SAMPLE MEASUREMENT	*****	*****		8.30		8.6	(12)	0	2 /30	GRAB
00400 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	******	******	**** ****	6.5 DAILY MN	******	9.0 DAILY MX	SU		TWICE/ MONTH	GRAB
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	*****	*****		****** 23.5	****** 46.0	46.0	(19)	1	2 /30	GRAB
00530 P 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT	******	******	**** ****	25 30DA AVG	35 MX 7D AVE	70 DAILY MX	MG/L		TWICE/ MONTH	GRAB
SOLIDS, SETTLEABLE	SAMPLE MEASUREMENT	*****	*****		******	******	<0.1	(25)	0	2 /30	GRAB
00545 P 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT	******	******	**** ****	******	******	0.5 DAILY MX	MG/L		TWICE/ MONTH	GRAB
OIL AND GREASE FREON EXTR-GRAV METH	SAMPLE MEASUREMENT	*****	*****		*****	*****	<2	(19)	0	2 /30	GRAB
00556 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	******	******	**** ****	******	******	10 DAILY MX	MG/L		TWICE/ MONTH	GRAB
IRON, TOTAL (AS FE)	SAMPLE MEASUREMENT	*****	*****		*****	*****	0.27	(19)	0	2 /30	GRAB
01045 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	******	******	**** ****	******	******	1.0 DAILY MX	MG/L		TWICE/ MONTH	GRAB
FLOATING SOLIDS OR VISIBLE FOAM-VISUAL	SAMPLE MEASUREMENT	*****	0	(94)	*****	*****			0	2 /30	VISUAL
45613 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	******	0	YES=1 NO=0	******	******	******	**** ****		TWICE/ MONTH	VISUAL

NAME/TITLE PRINCIPLE EXECUTIVE OFFICER		TELEPHONE		DATE		
KENNETH E. MAY MINE MANAGER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMAITON. I BELIEVE THE SUBMITTED INFORMATIONS IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE, AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statues may include fines up to $10,000 and or maximum imprisonment of between 6 months and 5 years.	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE 435	NUMBER 286-4880	YR 06	MO 06	DA 12
TYPED OR PRINTED						

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

DURING PRECIPITATION EVENTS (OR SNOWMELT OF EQUIVALENT VOLUME), SETTLEABLE SOLIDS & pH SHALL BE LIMITED INSTEAD OF THE OTHERWISE APPLICABLE LIMITATIONS. REPORT N/A IN THE APPROPRIATE BLANKS.

Sample taken on 05/04/06 was during a light rain. This sample did not exceed the TSS 70 MG/L limit but since it was the only sample taken for the week it exceeds the maximum weekly average of 35 MG/L.

PERMITEE NAME/ADDRESS
(Include Facility Name/Location if different)

NAME: Canyon Fuel Co., LLC
ADDRESS: SUFCO Mine
397 South 800 West
Salina, UT 84654
FACILITY: SUFCO Mine
LOCATION: SALINA

ATTN: KENNETH E. MAY, MINE MANAGER

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT *(DMR)*

(2-16) UT0022918 — PERMIT NUMBER

(17-19) 002 A — DISCHARGE NUMBER

MAJOR

F - FINAL
SEDIMENT POND
12" PIPE DISCHARGING FROM SEDIMENT POND

Form Approved
OMB No. 2040-0004

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
0 6	0 5	0 1	0 6	0 5	3 1
(20-21)	(22-23)	(24-25)	(26-27)	(28-29)	(30-31)

*** NO DISCHARGE [ ] ***

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53) AVERAGE	(54-61) MAXIMUM	UNITS 0	(4 Card Only) QUALITY OR CONCENTRATION (38-45) MINIMUM	(46-53) AVERAGE	(54-61) MAXIMUM	UNITS	NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
SANITARY WASTE DISCHARGED-ASSESSMENT	SAMPLE MEASUREMENT	*****	0	(94)	******	******	******		0	2 /30	VISUAL
45614 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	******	0	YES=1 NO=0	******	******	******	**** ****		TWICE/ MONTH	VISUAL
SOLIDS, TOTAL DISSOLVED	SAMPLE MEASUREMENT	*****	***** 80		****** 979	****** 1021	****** 1104	(19)	0	2 /30	GRAB
70295 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	******	2000 ****** LBS/DAY	**** **** LBS/DAY	******	******	******	**** ****		TWICE/ MONTH	GRAB
OIL AND GREASE VISUAL	SAMPLE MEASUREMENT	*****	0	(94)	******	******	******		0	2 /30	VISUAL
84066 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	******	0	YES=1 NO=0	******	******	******	**** ****		TWICE/ MONTH	VISUAL
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPLE EXECUTIVE OFFICER		TELEPHONE		DATE		
KENNETH E. MAY MINE MANAGER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMAITON. I BELIEVE THE SUBMITTED INFORMATIONS IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE, AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statues may include fines up to $10,000 and or maximum imprisonment of between 6 months and 5 years.	435	286-4880	06	06	12
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YR	MO	DA

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

DURING PRECIPITATION EVENTS (OR SNOWMELT OF EQUIVALENT VOLUME), SETTLEABLE SOLIDS & pH SHALL BE LIMITED INSTEAD OF THE OTHERWISE APPLICABLE LIMITATIONS. REPORT N/A IN THE APPROPRIATE BLANKS.

Sample taken on 05/04/06 was during a light rain. This sample did not exceed the TSS 70 MG/L limit but since it was the only sample taken for the week it exceeds the maximum weekly average of 35 MG/L.

0
0

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT *(DMR)*

ERMITEE NAME/ADDRESS
(Include Facility Name/Location if different)

AME Canyon Fuel Co., LLC
DDRESS SUFCO Mine
397 South 800 West
Salina, UT 84654
ACILITY SUFCO Mine
OCATION SALINA

(2-16) UT0022918 — PERMIT NUMBER

(17-19) 003 A — DISCHARGE NUMBER

MAJOR

F - FINAL
MINESITE
24" PIPE DISCHARGING MINE WATER

Form Approved
OMB No. 2040-0004

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
0 6	0 5	0 1	0 6	0 5	3 1
(20-21)	(22-23)	(24-25)	(26-27)	(28-29)	(30-31)

*** NO DISCHARGE [ ] ***

NOTE: Read instructions before completing this form.

.TTN: KENNETH E. MAY, MINE MANAGER

PARAMETER (32-37)		(3 Card Only) (46-53) AVERAGE	(54-61) MAXIMUM	UNITS 0	(4 Card Only) (38-45) MINIMUM	(46-53) AVERAGE	(54-61) MAXIMUM	UNITS	NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
FLOW RATE	SAMPLE MEASUREMENT	4.98	5.19	(03)	******	******	******		0	2 /30	MEASRD
00056 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	REPORT 30DA AVG	REPORT DAILY MX	MGD	******	******	******	**** ****		TWICE/ MONTH	MEASRD
PH	SAMPLE MEASUREMENT	*****	*****		7.12		7.17	(12)	0	2 /30	GRAB
00400 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	******	******	**** ****	6.5 DAILY MN	******	9.0 DAILY MX	SU		TWICE/ MONTH	GRAB
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	*****	*****		<5	****** <5	<5	(19)	0	2 /30	GRAB
00530 P 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT	******	******	**** ****	25 30DA AVG	35 MX 7D AV	70 DAILY MX	MG/L		TWICE/ MONTH	GRAB
SOLIDS, SETTLEABLE	SAMPLE MEASUREMENT	*****	*****		*****	*****	N/A	(25)			
00545 P 0 0 SEE COMMENTS BELOW	PERMIT REQUIREMENT	******	******	**** ****	******	******	0.5 DAILY MX	MG/L		TWICE/ MONTH	GRAB
OIL AND GREASE FREON EXTR-GRAV METH	SAMPLE MEASUREMENT	*****	*****		*****	*****	N/A	(19)			
00556 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	******	******	**** ****	******	******	10 DAILY MX	MG\L		TWICE/ MONTH	GRAB
IRON, TOTAL (AS FE)	SAMPLE MEASUREMENT	*****	*****		*****	*****	0.46	(19)	0	2 /30	GRAB
01045 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	******	******	**** ****	******	******	1.0 DAILY MX	MG/L		TWICE/ MONTH	GRAB
FLOATING SOLIDS OR VISIBLE FOAM-VISUAL		*****	0	(94)	*****	*****	*****		0	2 /30	VISUAL
45613 1 0 0 EFFLUENT GROSS VALUE			0	YES=1 NO=0	******	******	******	**** ****		TWICE/ MONTH	VISUAL

NAME/TITLE PRINCIPLE EXECUTIVE OFFICER		TELEPHONE		DATE		
KENNETH E. MAY MINE MANAGER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMAITON. I BELIEVE THE SUBMITTED INFORMATIONS IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE, AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statues may include fines up to $10,000 and or maximum imprisonment of between 6 months and 5 years.	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE 435	NUMBER 286-4880	YR 06	MO 06	DA 12
TYPED OR PRINTED						

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITEE NAME/ADDRESS
(Include Facility Name/Location if different)

NAME: Canyon Fuel Co., LLC
ADDRESS: SUFCO Mine
397 South 800 West
Salina, UT 84654
FACILITY: SUFCO Mine
LOCATION: SALINA

ATTN: KENNETH E. MAY, MINE MANAGER

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM *(NPDES)*
DISCHARGE MONITORING REPORT *(DMR)*

(2-16) UT0022918 — PERMIT NUMBER
(17-19) 003 A — DISCHARGE NUMBER

MAJOR
F - FINAL
MINESITE
24" PIPE DISCHARGING MINE WATER

Form Approved
OMB No. 2040-0004

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
0 6	0 5	0 1	0 6	0 5	3 1
(20-21)	(22-23)	(24-25)	(26-27)	(28-29)	(30-31)

*** NO DISCHARGE [ ] ***

NOTE: Read instructions before completing this form.

PARAMETER (32-37)		(3 Card Only) QUANTITY OR LOADING (46-53) AVERAGE	(54-61) MAXIMUM	UNITS 0	(4 Card Only) QUALITY OR CONCENTRATION (38-45) MINIMUM	(46-53) AVERAGE	(54-61) MAXIMUM	UNITS	NO. EX (62-63)	FREQUENCY OF ANALYSIS (64-68)	SAMPLE TYPE (69-70)
SANITARY WASTE DISCHARGED-ASSESSMENT 45614 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	0	(94)	******	******	******		0	2 /30	VISUAL
	PERMIT REQUIREMENT	******	0	YES=1 NO=0	******	******	******	**** ****		TWICE/ MONTH	VISUAL
SOLIDS, TOTAL DISSOLVED 70295 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****		******	******	709	(19)	0	2 /30	GRAB
	PERMIT REQUIREMENT	******	******	**** ****	******	******	1200 DAILY MX	MG/L		TWICE/ MONTH	GRAB
OIL AND GREASE VISUAL 84066 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	0	(94)	******	******	******		0	2 /30	VISUAL
	PERMIT REQUIREMENT	******	0	YES=1 NO=0	******	******	******	**** ****		TWICE/ MONTH	VISUAL
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPLE EXECUTIVE OFFICER
KENNETH E. MAY
MINE MANAGER
TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMAITON. I BELIEVE THE SUBMITTED INFORMATIONS IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION INCLUDING THE POSSIBILITY OF FINE, AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. § 1319. (Penalties under these statues may include fines up to $10,000 and or maximum imprisonment of between 6 months and 5 years.

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE		DATE		
AREA CODE	NUMBER	YR	MO	DA
435	286-4880	06	06	12

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

0